

# MAS Certified Green® Certificate of Compliance

## Low-Emitting Materials



Awarded to: **DURO DYNE CORPORATION**  
81 SPENCE STREET, BAY SHORE, NY 11706

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings  
Cert. Scheme: VOC Emissions

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*

\*Conforms With: Criteria of MAS Certified Green® Program  
LEED v4.1 & v5.0 ID+C, BD+C  
LEED TVOC Emissions at 14-days  
*low-emitting materials*  
*low-emitting materials*  
*0.5 mg/m<sup>3</sup> or less*

Certified Products: *SRPG Adhesive*

Test Date: September 15, 2025 Report No.:2500531 Certificate No.: MAS2500531-01DD

**Valid: September 2025 to September 2026**



Testing Cert. # 2925.01  
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017  
3<sup>rd</sup> Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012  
\*outside of A2LA accreditation scope

Page 1 Of 1

3945 Lakefield Ct. · Suwanee, Ga. 30024 · 770-866-3200 · <http://www.mascertifiedgreen.com/>