

MAS Certified Green® Certificate of Compliance

Low-Emitting Materials



Awarded to: **DURO DYNE CORPORATION**
81 SPENCE STREET, BAY SHORE, NY 11706

Category: Construction Materials - Interior Adhesives, Glues, Sealants & Coatings
Cert. Scheme: VOC Emissions, **VOC Content

Accredited Standards & Test Methods: California Dept. of Public Health Standard Method v1.2 *classroom & private office*
SCAQMD Rule 1168 (**VOC Content) *adhesive & sealant applications*

*Conforms With: Criteria of MAS Certified Green® Program *low-emitting materials*
LEED v4.1 & v5.0 ID+C, BD+C (VOC Emissions & Content) *low-emitting materials*
LEED TVOC Emissions at 14-days *0.5 mg/m³ or less*
US-CHPS Criteria 2.0 (2020) EQ C6.1.1 *adhesives & sealants*
Total VOC Content (less water) *6.0%, 69.0 g/L*

Certified Products: **WIT5LVAS & BWITLVAS.**

Test Date: July 27, 2026 Report No.: 2600297 Certificate No.: MAS2600297-02DD

Valid: July 2026 to August 2027



Testing Cert. # 2925.01
Product Cert. # 2925.02

Product Certifier, MAS Certified Green CT

Laboratory Testing by **ATS Labs, Marietta GA, 30062 - ISO/IEC 17025:2017 (#1888.02)

Laboratory Testing by **Materials Analytical Services, LLC** - ISO/IEC 17025:2017

Page 1 Of 1

3rd Party Product Certification by **MAS Certified Green®** - ISO/IEC 17065:2012

*outside of A2LA accreditation scope

3945 Lakefield Ct. • Suwanee, Ga. 30024 • 770-866-3200 • <http://www.mascertifiedgreen.com/>